ift-Nachweis

Number	19-000932-PR06 (NW-A01-0203-en-01)
Owner	Inoutic / Deceuninck GmbH Bayerwaldstr. 18 94327 Bogen Germany
Product	Tilt and turn casement door
Designation	System: Elegante
Details	Manufacturer Inoutic / Deceuninck GmbH, - Bogen; Material Unplasticised polyvinyl chloride (uPVC), with reinforcement; Type of opening Tilt and turn; Opening direction DIN right, inward opening; Overall dimensions (W x H) 1020 mm x 2470 mm
Special features	

Result

Air permeability according to EN 12207:2016-12	Resistance to wind load according to EN 12210:2016-03	Watertightness according to EN 12208:1999-11	Operating forces according to EN 13115:2001-07	Mechanical properties according to EN 13115:2001-07	Reveal and rebate hindrance test according to EN 13126-8:2017-11
					
4	**C5/B5**	**9A**	**1**	**4**	**fulfilled**

ift Rosenheim
20.05.2019

Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing

Franz Gruber
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006-03
*) and corresponding national versions (e.g. DIN EN)

Test report: 19-000932-PR06 PB-A01-0203-de-01

Representation



Instructions for use

The results obtained can be used by the manufacturer for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The provisions of the applicable product standard have to be observed.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

Identity-Check

www.ift-rosenheim.de/ift-geprueft
ID: 073-6DC56

ift Rosenheim GmbH
Theodor-Gietl-Str. 7-9
D-83026 Rosenheim

Contact
Phone: +49 8031 261-0
Fax: +49 8031 261-290
www.ift-rosenheim.de

Testing and Calibration – EN ISO/IEC 17025
Inspection – EN ISO/IEC 17020
Product Certification – EN ISO/IEC 17065
Certification of Management Systems – EN ISO/IEC 17021

Notified Body 0757
PÜZ-Stelle: BAY 18

ilac-MRA
DAkkS Deutsche Akkreditierungsstelle D-PL-11349-01-00